



CITY OF RIVERSIDE FIRE DEPARTMENT

Incident Information Fact Sheet



Incident Name: Rosewood

Incident Location: 3900 Block of Rosewood Place

Type of Incident: Natural Gas Leak

Incident Number: 16-017233

Date Reported: 06/22/2016

Time Reported: 2:58 PM

Fatalities: 0 **Critical:** 0 **Moderate:** 0 **Minor:** 0 **Non Injury:** 0

Transported Ground Ambulance(s): 0

Loss: \$0

Save: \$0

Cause: Construction

Control Time: 06/22/2016 1549

Evacuations: No

Evacuation Comments:

RESOURCES ASSIGNED

Fire Fighters: 3

Engine Companies: 1

Truck Companies: 0

Specialized Equipment:

Overhead Personnel: 1

Ambulance(s): 0

Water Tenders: 0

Utilities: Yes

Red Cross: No

Displaced Persons: No

CURRENT SITUATION

(Recent updates are posted at the top of Current Situation)

The City of Riverside Fire Department responded to a report of a natural gas leak in the 3900 block of Rosewood Place. The first arriving engine company discovered a work crew replacing curb and gutters on Rosewood Place had struck a service line to a residential house with a backhoe. The area was cordoned off and Rosewood Place was closed to vehicle traffic. The Gas Company responded out and had the gas shut off in under an hour. There were no evacuations of the residential houses and residents could access their houses.

COOPERATING AGENCIES

Riverside Streets, So. Cal Gas Co.